

## ADA Compliance Program

## CLARK COUNTY FACILITIES ACCESSIBILITY SURVEY 800 FRANKLIN STREET

Date of Survey: July 25, 2006

Conducted by: Teresa Guise – Clark County Plans Examiner

Tim McVicker - Clark County ADA Compliance Office

The building reviewed for accessibility is located at 800 Franklin Street at the intersection of Evergreen Blvd. It is a two-story structure. The first floor is being considered for occupancy by the Clark County Prosecutor's Office Child Support Division.

This is a business district and vehicular traffic is medium.

## Accessible Features:

- Accessible routes are currently in place which meet ANSI standards for accessibility
- Accessible off-street parking, access aisles and ramps are located near main entrance of the building.
- Large off-street parking area
- All door and hallway widths meet ANSI Standards for accessibility.

## Accessibility Concerns:

- Restrooms With a few minor improvements, one of the restrooms can be made accessible.
  Items needed: Toilet flush handle needs to be moved to the open side of the tank, cover facet pipes; lever handles on door, accessible restroom signage on latch side of door per ANSI specifications.
- A portion of reception counter should be constructed to meet ANSI standards for accessibility.
- Estimated Costs \$550.00

Recommendation: This facility should be considered as a location for the Child Support Office.